

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. 0007		3. EFFECTIVE DATE 25 AUG 98		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY Department of the Army Corps of Engineers Fort Worth District		CODE		7. ADMINISTERED BY (If other than Item 6)		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(✓)		9A. AMENDMENT OF SOLICITATION NO. DACA63-98-B-0040	
				X		9B. DATED (SEE ITEM 11) 27 JULY 1998	
						10A. MODIFICATION OF CONTRACTS/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE				FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(✓)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
 The Solicitation for GENERAL INSTRUCTION BUILDING, PHASE 1, FORT HOOD, TEXAS, is amended as follows:

See Continuation Sheet.

NOTE: Bid Opening Date remains "3 SEPTEMBER 1998, 2 p.m., local time" as previously announced.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
<div style="border-top: 1px solid black; text-align: center;"> (Signature of person authorized to sign) </div>		<div style="border-top: 1px solid black; text-align: center;"> (Signature of Contracting Officer) </div>	

NSN 7540-01-152-8070
PREVIOUS EDITION UNUSABLE
30-105-02
STANDARD FORM 30 (REV. 10-83)
Prescribed by GSA
FAR (48 CFR) 53.243
USAPPC V1.00

Item 14. Continued.

a. Specifications:

(1) Add the following paragraphs to Specification 16375, ELECTRICAL DISTRIBUTION SYSTEM, UNDERGROUND:

2.9.1.3 Integral Outgoing Section

Integral outgoing section shall be of the dead-front distribution panelboard/switchboard type. Each circuit breaker and auxiliary compartment shall have a suitable metal or laminated plastic nameplate with white cut letters at least 1/8 inch high on contrasting backgrounds as shown on the drawings. Manual key-interlock shall be provided as shown on the drawings with connections to the tie-breaker and main breakers. a. Dead-Front Distribution Panelboard/Switchboard Type: Outgoing section shall be of the panelboard/switchboard type mounted integrally with the transformer and shall consist of metering devices and main and branch circuit breakers mounted in panelboard/switchboard enclosures. Panelboards shall comply with NEMA PB 1. Switchboards shall comply with NEMA PB 2. Molded case breakers shall comply with paragraph METERING AND PROTECTIVE DEVICES. Plug-in circuit breakers are not acceptable. Directories to indicate loads served by each circuit shall be typed and mounted in holders provided on panelboard doors behind protective coverings. b. Metering: The main secondary bus of each outgoing section assembly shall include watt-hour demand meters with the necessary instrument transformers, Ampere meters, Voltage Meter, and VT and CT test blocks as shown on the drawings. Metering shall be as specified in paragraph METERING AND PROTECTIVE DEVICES. c. Ground Fault Protection: ground fault protection shall be provided utilizing sensors of the zero-sequence type or by the residual connection of phase and neutral current sensors.

2.18 SURGE ARRESTORS

Surge arresters shall comply with NEMA LA 1, IEEE 62.1, IEEE 62.2, and IEEE 62.1.1 and shall be provided where indicated. Arresters shall be intermediate class, rated as shown. Arresters shall be equipped with mounting brackets suitable for the indicated installations. Arresters shall be of the metal-oxide varistor type.

b. Drawings:

1. Add Notes to "Variable Air Volume Terminal Unit Schedule" on sequence no. 139, sheet M3:

a. VAV E101, E108, E201, E208: (Inlet air is 58 degrees F on all terminals), heating coil capacity remains as scheduled, LVG air Temp is allowed to rise to 105 degrees F.

b. VAV-E111, VAV-E211, VAV-F111, and VAV-F211: Provide control algorithm for these VAV terminals to proportionally re-open air valve on drop in space temperature below 70 F(0 cfm) to supply 327 cfm when space is at 68 degrees F for heating. CFM for reheat coil selection is 327 cfm.

2. Revise 120F to 135 F in the schedule "Variable Air Volume Terminal Unit Schedule" on sequence no. 139, sheet M3:

Revise all entering water temperature values for reheat coil selection on all terminals up to 135 degrees F.

3. Reference sequence no. 139, sheet M3, "Air Handling Unit Schedule".

Revise all entering water temperature values for preheat coil selection up to 135 degrees F.